

To: Alan Mills
RE: Reflection Lane Subdivision

05/29/06

A new irrigation system for Reflection Lane subdivision will be installed approximately as follows:


An expanded metal box screen will be placed in the canal for screening. The screen will be attached to a 10" steel pipe and deliver water to a 48" round concrete structure. The concrete structure will be 10' deep. A 15 hp turbine pump will pump from the concrete structure and into a Clemons 475 filter for further filtration. The pump will be controlled by a variable speed drive. The pump and controls will be covered with a 10' x 12' shed. One key will be issued to one person.

A 6" 125 psi PVC pipe will start at the pump station and be laid approximately 480' to the south on the East side of the Sterling property. At the concrete ditch the pipeline will be laid approximately 280' to the West to the end of the cul-de-sac. The pipeline will then tee and tie into the existing pipeline at McDonald's and Kimbrell's.

The existing pipelines will be capped in the SW corner of the Poyzer property and in the South landscaped area of the entrance. Caps will have concrete placed on them for thrust protection.

All new items shall be covered under a 1 year warranty.

Sincerely,



Jeff Forsberg
Agri-Lines Irrigation